



Creek County Rural Water District No. 2

2425 W. 121st Street South
Jenks, Oklahoma 74037
(TDD) 711
Phone (918) 299-4448
Fax (918) 299-5712
www.ccrwd2.com

Gentleman,

Creek County Rural Water District #2 has established a preferred parts material list with these brands being accepted.
NO OTHER BRAND NAME WILL BE ACCEPTED.

Tapping Sleeves: Smith-Blair, Ford, Mueller, or Rockwell

Gate Valves: AVK, Mueller, Preferred AVK, (American Flow Control Alpha only)

M/J Fittings: Tyler, US Pipe, Sigma, or United

Check Valves: OCV, Clow, Kennedy, or Golden Anderson

Pressure Reducing Valves: OCV, Val-Matic, or Golden Anderson

Air-Relief Valves: A.R.I., APCO, or Val-Matic

Restrained Joints: Midco Permagrip ONLY on all PVC Pipe 4" or smaller
For pipe 6" or larger: Midco, Meg-A-Lug, Star, EBBA, or Sigma

Fire Hydrants: AVK, Mueller, or American-Darling, Preferred AVK or Mueller

2" Post Hydrants: AVK or Mueller

Tracer wire must be solid core insulated 12 or 14 ga.

PVC Pipe shall conform to pressure class 200 and be "O-Ring" SDR21 rated.

Poly-Pipe shall conform to DR9.

No Glue Joint Pipe of any size will be accepted.

All brass must comply with the Lead Free Drinking Act of Jan. 4, 2011

Brass nipples and collars must be Domestic Brands ONLY. No Foreign brand will be accepted.

Only brass water fittings made by A.Y. McDonald, Ford, or Mueller will be accepted.

All material will need to be inspected before use.

Buried line must have 30" of cover or 36" through ditches and creeks.

No exposed trench can be back filled before approved inspection.

Please feel free to call Matt Foreman @ 918-830-1488 with any questions.